

FACILITIES BUILDING STANDARDS

Section 11 0000 Equipment

Publish date: **09/07/2018**

Emergency Eyewash and Shower Stations

- Locations for emergency eyewash and/or shower stations shall be determined by Shands Safety group. User groups must fill out risk assessment form as found in Core Policy CP05.703.

Flammable Cabinets

- Flammable cabinets must meet all OSHA and NFPA requirements. The cabinet must have tapered corners to prevent injury during loading/unloading, shall have self-closing doors for new purchases, has a fusible link door latch that releases in a fire situation. The desired product is Justrite 30 gallon Sure-Grip EX 893020, or coordinate with Owner (Safety group).

ADA Protrusion Limits

- People with vision impairments often travel closely along walls which can provide wayfinding cues sometime called a "shoreline." Objects mounted on walls, partitions, columns, and other elements along circulation paths can pose hazards unless their projection is limited to 4" maximum. Those with leading edges that are within cane sweep (27" high maximum) or that provide minimum headroom clearance (80" minimum) do not pose hazards and can protrude any amount.

Exception: Handrails shall be permitted to protrude 4 ½" maximum.

Limits of Protruding Objects

