

FACILITIES BUILDING STANDARDS

Section 21 0000 Fire Suppression

Update date: **02/07/2019**

-
1. All buildings shall be fully sprinklered, unless otherwise directed by owner.
 2. Use electric fire pump where fire pumps are required.
 3. Concealed fire sprinkler heads must be used at all drop-in ceiling tile or solid ceiling locations.
 4. Use ball drips at all fire department connection (FDC) locations.
 5. Use quick response fire sprinkler heads unless directed by Shands. In all conditions, do not mix head types within a zone or compartment.
 6. Use high temperature fire sprinkler heads above sterilizers and heat exchangers.
 7. Wet sprinkler piping shall use Schedule 40 pipe for sizes 2" and smaller with screwed fittings. All pipe 2½" and larger can be schedule 10 with roll grooved joints.
 8. Dry sprinkler piping must use Schedule 40 galvanized piping, with galvanized fittings.